



Intertek Testing & Certification Ltd
Intertek House, Cleeve Road,
Leatherhead, Surrey, KT22 7SB
United Kingdom

Phone : +44 (0) 1372 370900
Fax : +44 (0) 1372 370999
E-mail: cpd.uk@intertek.com
Web: www.intertek.com

EC CERTIFICATE OF CONFORMITY

0359-CPD-0046

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

FireCell Radio Cluster Communicator FC-555-001

(refer to attached appendix for details and conditions)

placed on the market by:

EMS Security Group Limited
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ

and produced in the factory by:

EMS Security Group Limited
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ

Is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. **0359 - Intertek Testing & Certification Ltd** – has performed the initial type- testing for the relevant characteristics of the product, the initial inspection of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the product performance described in Annex ZA of the product standards

EN 54-25:2008

- Fire detection and fire alarm systems - Components using radio links

were applied and that the product fulfils all the prescribed requirements.

This certification was issued **26th October 2010** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly and latest on **26th October 2015**



Daniel Griffin - Schemes Manager

Jerry Quayle - Director of Notified Body



Intertek Testing & Certification Ltd
Intertek House, Cleeve Road,
Leatherhead, Surrey, KT22 7SB
United Kingdom

Phone : +44 (0) 1372 370900
Fax : +44 (0) 1372 370999
E-mail: cpd.uk@intertek.com
Web: www.intertek.com

Appendix to EC Certificate of conformity 0359-CPD-0046

The details and condition of use for the FireCell Radio Cluster Communicator FC-555-001
placed on the market by:

EMS Security Group Limited
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ

To be used in accordance with the supplier's installation instructions.

Variants:

FireCell Radio Cluster Communicator FC-555-301
FireCell Radio Cluster Communicator FC-555-331

Conditions of use

1. Only to be used in conjunction with a power supply compliant to EN 54-4:1998 incorporating A1 and A2

General Notes:

1. Tested under Intertek project number 09041455.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This certification was issued on **26th October 2010** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly and latest on **26th October 2015**.



Daniel Griffin - Schemes Manager

Jerry Quayle - Director of Notified Body